

State of North Carolina Department of Environment, Health, and Natural Resources

Winston-Salem Regional Office

James G. Martin, Governor William W. Cobey, Jr., Secretary

Margaret Plemmons Foster Regional Manager

DIVISION OF ENVIRONMENTAL MANAGEMENT GROUNDWATER SECTION

May 13, 1991

Tom Brock, Facilities Engineer American Drew, Plant #14 P.O. Box 489 North Wilkesboro, NC 28659-0489

SUBJECT: UST Systems Closure And Corrective Action At American Drew #14, Highway 268 East, Elkin, Wilkes County

Dear Mr. Brock:

The Groundwater Section of the Division of Environmental Management has been reviewing its active files which show no recent correspondence. The last entry in the file for the subject location is your correspondence of November 13, 1989, which indicated soil contamination of 731 ppm TPH.

At your earliest possible convenience, please submit confirmation that all contaminated soil has been removed from the tank pit excavation and remediated to <10 ppm TPH.

If you have any questions, please feel free to contact me at the letterhead address or telephone number.

Sincerely,

Thomas A. Salley

Hydrogeological Technician

Theme a Sallen

TAS/ahl

cc: WSRC

Central Files - Wilkes County